

DECLARATION OF PERFORMANCE

No: 0832-CPD-0954

Product(s) Identification Code:

CXM Call Point

Type, Batch or serial number or any other element allowing identification of the construction products(s) as required pursuant to Article 11(4):

CXM/CO/GP/R/BB

Intended use or uses of the construction product, in accordance with the applicable harmonised technical specification, as foreseen by the manufacturer:

Fire detection and fire alarm systems

Name, registered trade name or registered trade mark and contact address of the manufacturer as required pursuant to Article 11(5):

Cooper Fulleon Limited, Llantarnam Park, Cwmbran, South Wales, NP44 3AW

Where applicable, name and contact address of the authorized representative whose mandate covers the tasks specified in Article 12(2):

Not Applicable

System or systems of assessment and verification of constancy of performance of the construction product as set out in Annex V:

System 1

In case of the declaration of performance concerning a construction product covered by the harmonized standard:

BRE, Garston, Watford, Hertfordshire, WD25 9XX, United Kingdom.

performed type testing and the initial inspection of the manufacturing plant and of the factory production control with continuous surveillance assessment and approval of the factory production control under system 1 and issued the EC certificates of conformity:

0832-CPD-0954

Declared performance:


All requirements including all Essential Characteristics and the corresponding performances for the intended use or uses indicated in point 3 above have been determined as described in the hEN mentioned in the table below.

Essential Characteristics	Performance	Harmonized Technical Specification
		EN54-11:2001 + A1:2005
Nominal activation conditions / sensitivity, Performance under fire conditions	Pass	4.3.2, 4.4, 4.7.1, 4.7.4, 5.2, 5.3
Operational reliability	Pass	4.2, 4.3.1, 4.5, 4.6, 4.7.2, 4.7.3, 4.7.5, 4.8, 5.4, 5.5
Durability Of Operational Reliability, Temperature Resistance	Pass	5.7, 5.9
Durability Of Operational Reliability, Humidity Resistance	Pass	5.10, 5.12
Durability Of Operational Reliability, Corrosion Resistance	Pass	5.11, 5.13
Durability Of Operational Reliability, Vibration Resistance	Pass	5.14 to 5.17
Durability Of Operational Reliability, Electrical Stability	Pass	5.6

The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 9.

This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4. Signed for and on behalf of Cooper Fulleon Limited by:

16th October 2015 - Cwmbran
Date and Place of Signature


Mr Philip Williams, Approvals Manager