



## Certificate of constancy of performance for products

In compliance with the Regulation 305/2011/UE of the European Parliament and of the Council of 9 March 2011.  
(Construction Products Regulation or CPR)

**Delivered by :**

Notified Body : **AFNOR Certification**  
Identification number : **0333**  
Address : **11 rue Francis de Pressensé  
FR - 93571 LA PLAINE SAINT-DENIS CEDEX**

**Delivered to :**

Company: **EATON ELECTRICAL PRODUCTS LIMITED**  
Address : **Llantarnam Park, Cwmbran  
GWENT NP44 3AW - United Kingdom**

Manufacturing site(s) : **Gwent - United Kingdom**

**Product:** **Visual alarm device - ROLP LX WALL BASE**

**Detailed description of product:** Appendix

AFNOR Certification attests that the provisions concerning the assessment and verification of constancy of performance and the performances described in annex ZA of the standard(s), below stated, under system 1 are applied and that the product fulfills the provisions described in annex ZA of the standard(s) below designated.

**Fire detection and fire alarm systems**

**EN 54-23:2010 - Fire alarm devices - Visual alarm devices**

**Certificate number :** **0333-CPR-075444**

**Certificate expiry date :** **25 May 2023**

This certificate was first issued on 9 August 2013. Unless suspension or canceled, this certificate remains valid as long as the conditions laid down in the reference technical specifications or the manufacturing conditions in the factory or the factory production control or the product itself are not modified significantly.

It cancels and replaces the certificate issued on 20 December 2017.

**Date of certificate delivery :** **25 May 2018**



**Franck LEBEUGLE**  
Managing Director of AFNOR Certification



# Certificat

Certificate

## Appendix to the certificate

Company : EATON ELECTRICAL PRODUCTS LIMITED  
Certificate number : 0333-CPR-075444  
Manufacturing site(s) : Gwent - United Kingdom  
Date of certificate delivery : 25 May 2018

### Product's description :

Identification of certified product(s) (Reference)	Product designation / Use	File number
ROLP LX WALL BASE	Visual alarm device Type B (outdoor) Category : W (wall mounted) Light colour : White or Red	075.1469 075.2043 075.2225

This appendix cannot be submitted or reproduced without the document to which it is attached.

Franck LEBEUGLE  
Managing Director of AFNOR Certification

